



## Shutter Fire Damper



### Specifications

- Galvanised steel blades as standard
- Blade pack contained out of air stream as standard
- Minimum two hour fire rated in accordance with B.S. 476 Part 20 Test no CHILT / 01083
- Ferretic Stainless blades available LPC test no T.E.82125
- Quick release fusible link mechanism for ease of testing and resetting
- Standard link 72 deg C higher ratings available
- Suitable for low, medium and high pressure application
- High torque stainless steel constant force springs enable damper to be installed in vertical or horizontal positions
- Visual indicator optional
- Intumescent liner fitted between damper case and installation frame to enable case to expand whilst maintaining total fire integrity between case and fire wall
- Conforms to recommendations of D.W.144
- Installation frames available to suit all site requirements
- Flanged version available
- Detail of test report available on written request

Fire

Smoke

Volume Control

Smoke/Fire

Smoke/Pressure

**SAFEAIR LTD**  
Slackstead Business Park,  
Upper Slackstead, Farley Lane,  
Braishfield, Hants. SO51 0QL

**TEL:** 01794 367360  
**FAX:** 01794 367361  
info@safeairproducts.co.uk  
www.safeairproducts.co.uk